

CITY OF SAN ANGELO PURCHASING DEPARTMENT 72 West College Avenue, San Angelo, Texas 76903 Tel: (325) 657-4219 or 657-4220

## Addendum 1

Date: April 9, 2015

RFP NO: ES-01-15/ 19<sup>th</sup> Street Sidewalk

## Bid Date: April 22, 2015/2:00 PM Local Time

The following clarifications, changes, additions, and/or deletions are hereby made to the specifications and contract documents:

- The Project Number for 19<sup>th</sup> Street Sidewalks is ES-01-15. Any prior reference to ES-05-14 should be updated to ES-01-15. Headings on the Project Plans were updated with this administrative change and are attached.
- The General Notes/Specifications section of the Project Plans has been updated to show "The Contractor shall use 4" thick Class "A" concrete with 36 pounds per cubic yard of Novamesh 850 or an approved equivalent on all sidewalks and 6" thick on driveways."

It is the responsibility of the bidder to ensure all addendums are considered in their pricing to prior to submitting a bid by contacting the Purchasing Department or visiting the city's website at <u>www.cosatx.us</u>. All addendums are published on the website as they are issued. Failure to do so will be at the risk of the respondent.

Sincerely,

Julia Antilley Purchasing Manager <u>SAPurch@cosatx.us</u>