

**NOTICE TO PROSPECTIVE CONTRACTORS**

This addendum shall be considered as part of the Drawings, General Documents, and specification for the above named project as though the items had been issued at the same time and incorporated integrally with the Drawings, General Documents and Specifications. Wherein provisions of the following amendments contained in this Addendum differ from the provisions of the original drawings, General Documents and specifications, the provisions of this Addendum shall govern and take precedence.

Contractors are hereby notified that they are to make any adjustments in their estimates that they may deem necessary on account of this Addendum. It will be considered that each Contractor's Proposal is submitted with full knowledge of all modifications and changes specified herein. This Addendum shall become a component of the Contract Documents.

This Addendum shall be inserted inside the front cover of the Project Manual by each prospective contractor.

**Item #1**      The City of San Angelo Vendor will furnish and install the fire alarm system equipment and the security system equipment. The General Contractor is responsible to schedule these installations. The Electrical Contractor is responsible to install the infrastructure and rough-ins (ie, conduit, boxes, etc.) for these two systems.

**Item #2**      Control the exterior light fixtures Type "P" and Type "Q" with a photocell and time clock. Provide contactor and relays as required. Time clock shall have battery backup to maintain its schedule in the event of power loss.

Please contact me at 325-659-2235 for any questions.



September 5, 2017

Paul R. Wilkerson, PE  
State of Texas #50732  
Firm #F-6257

---

**PowerSystems, Incorporated**

P.O. Box 2863 • San Angelo, Texas 76902 • Phone: (325) 659-2235