



CITY OF SAN ANGELO
PURCHASING DIVISION
72 West College Avenue, San Angelo, Texas 76903
Tel: (325) 657-4219

ADDENDUM 1

Date: December 8, 2017

RFB No: COL-01-18 / Coliseum Chiller

Bid Date: ~~January 23, 2018/2:00PM~~ ~~December 18, 2017/2:00 PM~~ Local Time

The following clarifications, changes, additions, and/or deletions are hereby made to the RFB:

- The Bid Due Date has been extended to January 23, 2018 at 2:00PM.
- Price must be valid for sixty (60) days from bid due date.
- No chemical treatment of water is necessary.
- The dimensions of the existing concrete pad are 7'6" wide and 29' long. Units extending beyond the pad may require additional concrete for the walk path.
- Contractor shall provide Pressure Transmitters into the Coliseum Chilled Water Supply and Spur Chilled Water Supply for pump speed drive controls; Install two (2) ¾ taps with ball valves for the pressure sensors for each line.
- **INVITATION TO BID, General (pg. 1)** shall be updated to clarify type of unit from RTAC to RTAF.
- **Specifications Worksheet (pg. 24) Item 1** shall be updated to clarify type of unit from RTAC to RTAF.

It is the responsibility of the vendor to ensure all addenda are considered in their pricing prior to submitting a bid by contacting the Purchasing Division at SAPurch@cosatx.us. Failure to do so will be at the risk of the vendors. No revisions to a bid can be allowed after the bids are opened for any reason.

Sincerely,

A handwritten signature in blue ink that reads "Candice Blake".

Candice Blake
Purchasing Specialist