

ADDENDUM 3

Date: July 20, 2018

RFB No: PK-03-18 / Renovation and Expansion of Ruffini Parking Lot

Bid Date: July 26, 2018/2:00 PM Local Time

The following clarifications, changes, additions, and/or deletions are hereby made to the RFB:

 Can you please clarify the type of pavement markings required for the project, Type 1 or Type 2? Type 2 is typically standard for parking lots, but the plans do not specify a type. Type 2 – Traffic paint is acceptable.

For other questions or clarifications, please contact the Purchasing Division at SAPurch@cosatx.us.

Sincerely,

Chris Webber

Purchasing Specialist