



**CITY OF SAN ANGELO**  
**PURCHASING DIVISION**  
72 West College Avenue, San Angelo, Texas 76903  
Tel: (325) 657-4219

## **ADDENDUM 1**

**Date: September 28, 2018**

**RFB No: ES-08-18 / REBID – West Concho Avenue Improvements**

**Bid Date: October 10, 2018/2:00 PM Local Time**

The following clarifications, changes, additions, and/or deletions are hereby made to the RFB:

- The pre-bid questions section of this addendum documents all questions received by September 28, 2018 with responses. If a question warranted a change to the bid documents then those changes are reflected in the addenda and supporting documentation. If a question did not warrant a change to the bid documents, a response is provided.

It is the responsibility of the vendor to ensure all addenda are considered in their pricing prior to submitting a bid by contacting the Purchasing Division at [SAPurch@cosatx.us](mailto:SAPurch@cosatx.us). Failure to do so will be at the risk of the vendors. No revisions to a bid can be allowed after the bids are opened for any reason.

Sincerely,

A handwritten signature in blue ink that reads "Candice Blake".

Candice Blake  
Purchasing Manager

## PRE-BID QUESTIONS/CLARIFICATIONS

QUESTIONS SUBMITTED AS OF: SEP 28, 2018			
NUM	QUESTION	RESPONSE	ACTION
1	Shouldn't the barricade items be increased from the first bid since this is a working day contract and not a calendar contract? The bid documents state 150 working days or 30 standard work weeks which would calculate to 210 calendar days or 7 months.	REVISE COSA BID ITEM 13 QTY TO 5 MOS	SEE A1-1
2	Bid item 32 on the TXDOT bid form is formatted incorrectly. The quantity is 47.5 but is shown as 48.	CHANGE QTY TO READ 47.5	SEE A1-2
3	On past projects, there had been a bid item to adjust the water valve boxes to grade. Was this an oversight or should this be subsidiary to the concrete pavement?	SUBSIDIARY TO SETTING VALVES. SEE PROJECT MANUAL 3.3.1.2. NO ADJUSTMENTS TO EXISTING VALVE BOXES ARE EXPECTED.	NONE
4	The plans show to install 24" HDPE (plastic pipe) storm drain pipe but the bid item is for 24" RCP?	USE BID ITEM RCP	NONE
5	There is no detail for backfill requirements for the 24" storm drain pipe? Might want to use a 2-sack backfill in the roadway.	USE 2 SACK BACKFILL	NONE
6	What is the thickness of the existing concrete pavement?	REVISE BID ITEM	SEE A1-3
7	Item 9 in Addendum 2 stated to use the reinforcement for the concrete pavement as shown on Detail C1 Plan Sheet C-103 (#4 – 18" o.c.e.w.). The bid item still shows CRCP (continually reinforced concrete pavement) which is completely different from the reinforcement shown in the plans. Shouldn't the bid item just say CONC PVMT (REINF) (6")?	REVISE BID ITEM	SEE A1-4
8	Note 3 on sheet C-103 indicates a 6" wide fire lane stripe on the face of the curb? On all curbs? There's no pay item for this work?	DELETE REQUIREMENT. NO FIRE LANE MARKING REQUIRED.	NONE
9	What type of mix will be required for the Flexible Pavement Structure Repair?	TYPE D HOT-MIXED COLD-LAID AC PVMT	NONE
10	Shouldn't the Flexible Pavement Structure Repair be 6" since it's adjacent to the 6" concrete pavement?	REVISE BID ITEMS	SEE A1-5
11	What is the bid item "CL B CONC (MISC) CY" for?	TRAFFIC SIGNAL BID ITEM SUMMARY TABLE TS-104. TS-CF-04 CONTROLLER CABINET SLAB	NONE
12	There are no bid items for connections to existing waterlines?	ADD COSA BID ITEMS FOR TAPPING SLEEVE & VALVES	SEE A1-6

## ADDENDUM 1 ITEMS

### A1-1 COSA Bid Item 13, Barricades, Signs and Traffic Handling

Revise quantity to be “ **5** ”.

### A1-2 TXDOT Bid Item 32, Aluminum Sign (TY A)

Revise quantity to read “ **47.5** ”.

### A1-3 COSA Bid Item 1, Removing Conc (PAV)

Revise description to read; “ **REMOVING CONC (PAV) (6”-8”)** “

### A1-4 COSA Bid Item 10, Conc Pvmt

Revise description to read; “ **CONC PVMT (REINF) (6”)** “

### A1-5 COSA Bid Item 9 & TXDOT Bid Item 4; Flexible Pavement Repair

Revise description to read; “ **FLEXIBLE PAVEMENT STRUCTURE REPAIR (6”)** “

### A1-6 Add the following COSA Bid Items

NO.	SPEC	CODE	DESCRIPTION	UNIT	COSA QTY	UNIT PRICE	AMOUNT
53	2667	012	18” X 18” TAPPING SLEEVE & VALVE	EA	2		
54	2667	013	10” X 10” TAPPING SLEEVE & VALVE	EA	1		
55	2667	014	8” X 8” TAPPING SLEEVE & VALVE	EA	2		
56	2667	015	8” X 6” TAPPING SLEEVE & VALVE	EA	1		