

## ADDENDUM 1

Date: May 24, 2019

RFWQ No: WU-08-19 / Water Conservation Kits

Bid Date: June 5, 2019/2:00 PM Local Time

The following clarifications, changes, additions, and/or deletions are hereby made to the RFWQ:

- Respondents should provide pricing for <u>chrome</u> shower heads
- Shower heads should have a flow rate ≤ 1.5 GPM (Gallons per Minute)
- Kitchen aerators should swivel
- Pause valves are not necessary

For other questions or clarifications, please contact the Purchasing Division at <a href="mailto:SAPurch@cosatx.us">SAPurch@cosatx.us</a>.

Sincerely,

Nolan A. Sosa Purchasing Manager