



City of San Angelo

Water Quality Laboratory

1324 Metcalfe St.
San Angelo, TX 76903
Ph: 325.481.2722 - Fax: 325.653.7278



LABORATORY REPORT

Report To: City of San Angelo
Water Production Plant
327 W. Ave I
San Angelo, TX 76903

Lab Number: 639
Collected: 9:15:00 AM
Received: 11/12/2024
Reported: 11/12/2024

Project Name: Water Quality Laboratory
Contact: Elena Velez-Reyes
Sample ID: Tap Sample

Analyte	Results	Units	Test Date	By	DL	Method
Aluminum (Al)	0.10	mg/L	11/12/2024	AJC	0.1	Hach 8012
Ammonia nitrogen (NH3-N)	0.82	mg/L	11/12/2024	AJC	0.015	Hach 10205
Bicarbonate (HCO3)	156	mg/L	11/12/2024	AJC	4	SM 2320-B
Calcium (as Ca)	83	mg/L	11/12/2024	AJC	4	SM 3500-Ca-B
Chloride (Cl)	340	mg/L	11/12/2024	AJC	4	SM 4500-Cl-B
Conductivity	1465	µs	11/12/2024	AJC	1	SM 2510-B
Fluoride (F)	0.55	mg/L	11/12/2024	AJC	0.1	Hach 8029
Iron (Fe)	0.01	mg/L	11/12/2024	AJC	0.01	Hach 8008
Magnesium (as Mg)	56	mg/L	11/12/2024	AJC	4	SM 3500-Mg-B
Nitrate nitrogen (NO3-N)	0.23	mg/L	11/12/2024	AJC	0.23	Hach 10206
Ortho-phosphate (PO4)	0.06	mg/L	11/12/2024	AJC	0.06	Hach 8048
pH Value	8.0	units	11/12/2024	AJC		SM 4500-H+
Potassium (K)	11.0	mg/L	11/12/2024	AJC	5	Hach 8049
Sodium (Na)	199	mg/L	11/12/2024	AJC	4	calc.
Sulfate (SO4)	263	mg/L	11/12/2024	AJC	10	Hach 10227
Total Alkalinity (as CaCO3)	128	mg/L	11/12/2024	AJC	4	SM 2320-B
Total Dissolved Solids (TDS)	938	mg/L	11/12/2024	AJC	5	calc.
Total Hardness (as CaCO3)	436	mg/L	11/12/2024	AJC	4	SM 2340-C
Total Hardness (in Grains)	25.7	gr/gal	11/12/2024	AJC		SM 2340-C

cc: Lab File

Elena Velez-Reyes
Laboratory Manager